IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for Moorefield Municipal Water WV3301601

Our water system violated drinking water monitoring requirements within the past year. Even though these were not emergencies, you, as our customers, have a right to know what happened and what we did to correct the situation. We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During periods listed in the table below, we did not monitor or test as required and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the monitoring we did not conduct, how often we are supposed to sample and when the samples should have been taken.

Required Monitoring	Required Monitoring Frequency	Compliance Period
Disinfectant By-Product (DPB) sampling. Monitoring Trihalomethanes (TTHM) (Type 27)	Quarterly	07/01/2021 to 09/30/2021
Failure to Monitor Total Organic Carbon (Type 27)	Quarterly	07/01/2009 to 09/30/2009
Failure to Monitor Lead and Copper (Type 52)	6 month	01/01/2022 to 06/30/2022
Failure to Monitor Arsenic, Inorganics, Nitrate, Volatile Organics (Type 03)	Annual	01/01/2022 to 12/31/2022

What happened? What is being done?

There was a clerical error on a lab report and a misunderstanding of the monitoring schedule.

All these samples have been subsequently tested and all results are satisfactory.

For more information, please contact Jim Iman at 304-530-6067 or 206 Winchester Avenue.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Moorefield Municipal Water

State Water System ID# WV3301601

Date Distributed <u>AUGUST 3, 2023</u>